



August 22, 2008

ADDENDUM NO. 1 TO ALL BIDDERS:

Invitation to Bid: IFB # 09-08-02

Description: AUTOMATIC STANDBY DIESEL GENERATOR

Dated: August 22, 2008

For Delivery to: Purchasing Division, Room 202, City of Roanoke, Virginia

Bid Due: September 19, 2008

ADD THE FOLLOWING:

SECTION 8. MISCELLANEOUS

J. The City will use Ultra Low Sulfur Diesel (ULSD) with a Bio-diesel component of 0 – 20% in the Generator specified in this IFB. Each Bidder shall submit with their response any issues or concerns regarding the equipment and/or the warranty if such fuel component is used. If concerns are not addressed before or at the time of the bid opening (or in advance for equal substitutions approved) the City will use this addendum as confirmation that all warranties apply regardless of the fuel used in such Generator.

Note: A signed acknowledgment of this addendum should be received at the location indicated on the IFB either prior to the due date and hour or attached to your response. Signature on this addendum does not substitute for your signature on the original bid document. The original bid document must be signed. Faxed acknowledgement will be accepted.

Very truly yours,

Sharon T. Gentry
Purchasing Manager
Phone: 540-853-2871
Fax: 540-853-1513

Name of Firm

Signature/Title

Date