

Fire Lane Signs

1. Specifications for fire lane signs are as follows:

A. Fire lane signs shall be installed as follows:

- A sign shall be positioned at the beginning and end of the fire lane and at 100 foot intervals throughout the fire lane or as designated by the fire official.
- Signs shall be mounted on posts and must not exceed a setback of 6 feet from the curb or edge of the roadway.
- The sign shall be positioned where clearly visible to traffic.
- The sign is to be mounted not less than 7 feet from the ground to the bottom of the sign, unless otherwise directed.
- Signs shall not be obscured from view by bushes, shrubs, etc.
- Signs shall be installed on the side of direction of travel and shall face the traffic they are intended to serve.

B. Sign Lettering and Construction

- Preferred lettering on sign: **NO PARKING FIRE LANE TOWING ENFORCED**
arrows to point to and indicate the area designated as fire lane. (see example sheet)
- Acceptable lettering on sign: **FIRE LANE NO PARKING**.

- Red letters on white background with 3/8" red stripe around the entire outer edge of the sign.

- Lettering size as follows:

No Parking --- Fire Lane - 2"

Towing Enforced - 1"

Arrow - 1"

- Metal construction, approximately 12" x 18".

- All signs shall be made of reflectorized sheeting and conform to the Manual on Uniform Traffic Control Devices published by the Federal Highway Administration.

